

Approval Number 2209549
Test Report: J-00435009



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

23rd November 2022

Metallux S.A.
Via Moree 12,
CH-6850 Mendrisio,

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

CERAMIC

5023

[Redacted] White coloured ceramic diaphragm manufactured by casting. For use with water up to 85°C.

APPROVAL NUMBER: 2209549
APPROVAL HOLDER: METALLUX S.A.

The Scheme reserves the right to review approval.
Approval 2209549 is valid between September 2022 and September 2027

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a horizontal line extending to the right.

Ian Hughes
WRAS Approvals Manager

Approval Number 2209548
Test Report: J-00435008



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

23rd November 2022

Metallux S.A.
Via Moree 12,
CH-6850 Mendrisio,

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

CERAMIC

5023

White coloured ceramic diaphragm manufactured by casting. For use with water up to 85°C.

APPROVAL NUMBER: 2209548
APPROVAL HOLDER: METALLUX S.A.

The Scheme reserves the right to review approval.
Approval 2209548 is valid between September 2022 and September 2027

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', is written over a white background.

Ian Hughes
WRAS Approvals Manager

Approval Number 2209540
Test Report: J-00435007



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

23rd November 2022

Metallux S.A.
Via Moree 12,
CH-6850 Mendrisio,

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

CERAMIC

5023

 White coloured ceramic diaphragm manufactured by casting. For use with water up to 85°C.

APPROVAL NUMBER: 2209540
APPROVAL HOLDER: METALLUX S.A.

The Scheme reserves the right to review approval.
Approval 2209540 is valid between September 2022 and September 2027

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a horizontal line extending to the right.

Ian Hughes
WRAS Approvals Manager